

FOREST PARK PFAS RESULTS IN FINISHED WATER

2016 - Present

PFOA

SAMPLE DATE		PFOA
YEAR	MONTH	PPT
2016	JUNE	ND
2016	OCTOBER	ND
2016	NOVEMBER	ND
2016	DECEMBER	2.2
2017	JANUARY	2.6
2017	FEBRUARY	2.0
2017	MARCH	2.8
2017	APRIL	2.9
2017	MAY	2.9
2017	JUNE	3.0
2017	JULY	3.0
2017	AUGUST	2.8
2017	SEPTEMBER	2.3
2017	NOVEMBER	2.5
2017	DECEMBER	2.4
2018	JANUARY	3.3
2018	FEBRUARY	3.4
2018	MARCH	3.2
2018	APRIL	3.0
2018	MAY	4.1
2018	JUNE	4.2
2018	JULY	4.0
2018	AUGUST	4.5
2018	SEPTEMBER	4.3
2018	OCTOBER	4.4
2018	NOVEMBER	4.5
2018	DECEMBER	4.5
2019	JANUARY	4.2
2019	FEBRUARY	3.7
2019	MARCH	3.6
2019	JUNE	4.2
2019	JULY	2.6
2019	AUGUST	2.4
2019	SEPTEMBER	2.5
2019	OCTOBER	2.1
2019	NOVEMBER	3.0
2019	DECEMBER	2.4
2020	JANUARY	2.1
2020	FEBRUARY	ND
2020	MARCH	2.0
2020	APRIL	2.4
2020	MAY	ND
2020	JUNE	ND
2020	JULY	ND
2020	AUGUST	ND
2020	SEPTEMBER	ND
2020	OCTOBER	ND
2020	NOVEMBER	2.3
2020	DECEMBER	2.0
2021	JANUARY	2.3
2021	FEBRUARY	2.5
2021	MARCH	2.2

PFOS

SAMPLE DATE		PFOS
YEAR	MONTH	PPT
2016	JUNE	ND
2016	OCTOBER	ND
2016	NOVEMBER	ND
2016	DECEMBER	ND
2017	JANUARY	ND
2017	FEBRUARY	ND
2017	MARCH	2.1
2017	APRIL	ND
2017	MAY	ND
2017	JUNE	ND
2017	JULY	ND
2017	AUGUST	ND
2017	SEPTEMBER	ND
2017	NOVEMBER	ND
2017	DECEMBER	ND
2018	JANUARY	ND
2018	FEBRUARY	2.0
2018	MARCH	ND
2018	APRIL	ND
2018	MAY	2.3
2018	JUNE	2.3
2018	JULY	2.2
2018	AUGUST	2.3
2018	SEPTEMBER	ND
2018	OCTOBER	2.3
2018	NOVEMBER	2.3
2018	DECEMBER	2.2
2019	JANUARY	2.2
2019	FEBRUARY	2.4
2019	MARCH	2.5
2019	JUNE	2.4
2019	JULY	ND
2019	AUGUST	ND
2019	SEPTEMBER	ND
2019	OCTOBER	ND
2019	NOVEMBER	2.4
2019	DECEMBER	ND
2020	JANUARY	ND
2020	FEBRUARY	ND
2020	MARCH	ND
2020	APRIL	ND
2020	MAY	ND
2020	JUNE	ND
2020	JULY	ND
2020	AUGUST	ND
2020	SEPTEMBER	ND
2020	OCTOBER	ND
2020	NOVEMBER	ND
2020	DECEMBER	ND
2021	JANUARY	ND
2021	FEBRUARY	ND
2021	MARCH	ND

2021	APRIL	2.2
2021	MAY	ND
2021	JUNE	2.1
2021	JULY	2.5
2021	AUGUST	2.5
2021	SEPTEMBER	2.5
2021	OCTOBER	2.2
2021	NOVEMBER	2.3
2021	DECEMBER	ND
2022	JANUARY	2.3
2022	FEBRUARY	3.0
2022	MARCH	2.4
2022	APRIL	2.3
2022	MAY	3.2
2022	JUNE	2.6
2022	JULY	2.9
2022	AUGUST	2.5
2022	SEPTEMBER	2.5
2022	OCTOBER	2.3
2022	NOVEMBER	2.1
2022	DECEMBER	2.2
2023	JANUARY	2.3
2023	FEBRUARY	2.3
2023	MARCH	ND
2023	APRIL	ND
2023	MAY	2.5
2023	JUNE	2.2
2023	JULY	3.0
2023	AUGUST	2.5
2023	SEPTEMBER	2.5
2023	OCTOBER	4.1
2023	NOVEMBER	2.0
2023	DECEMBER	2.6
2024	JANUARY	2.8

2021	APRIL	ND
2021	MAY	ND
2021	JUNE	ND
2021	JULY	ND
2021	AUGUST	ND
2021	SEPTEMBER	ND
2021	OCTOBER	ND
2021	NOVEMBER	ND
2021	DECEMBER	ND
2022	JANUARY	ND
2022	FEBRUARY	ND
2022	MARCH	ND
2022	APRIL	1.8
2022	MAY	2.1
2022	JUNE	ND
2022	JULY	2.0
2022	AUGUST	ND
2022	SEPTEMBER	ND
2022	OCTOBER	ND
2022	NOVEMBER	ND
2022	DECEMBER	ND
2023	JANUARY	ND
2023	FEBRUARY	2.1
2023	MARCH	ND
2023	APRIL	ND
2023	MAY	2.8
2023	JUNE	ND
2023	JULY	2.2
2023	AUGUST	2.2
2023	SEPTEMBER	2.2
2023	OCTOBER	2.0
2023	NOVEMBER	ND
2023	DECEMBER	ND
2024	JANUARY	ND

Note: "ND" means that there has been no contamination detected. Lab detection limit is down to 1.9 PPT